ISBN 0-7729-2566-6

STONEY POINT

WATER TREATMENT PLANT

DRINKING WATER SURVEILLANCE PROGRAM

ANNUAL REPORT - 1986

MAY, 1987

Ontario
Ministry of the Environment

J. Bishop, Director
Water Resources Branch

STONEY POINT WATER TREATMENT PLANT

DRINKING WATER SURVEILLANCE PROGRAM

ANNUAL REPORT - 1986

ISBN 0-7729-2566-6

MAY, 1987

ONTARIO MINISTRY OF THE ENVIRONMENT

Southwestern Region

STONEY POINT WATER TREATMENT PLANT

Location:	6011 St. Clair Road West P.O. Box 70 Stoney Point, Ontario NOR 1NO (519-798-3313)
Source:	Lake St. Clair
Design Capacity:	4.45 1000 M3/day
Operation:	Municipal
Plant Superintendent:	G. Scroggins
Ministry Region:	Southwestern Region Windsor District Office 250 Windsor Avenue, 6th Floor Windsor, Ontario N9A 6V9 (519-254-2546)
Municipalities Served:	Tilbury North (3,155) Tilbury West (326)
Treatment Type:	Physical and chemical treatment consisting of coagulation, flocculation sedimentation and filtration (conventional) and disinfection.
Chemicals Used:	Coagulation - alum liquid Post chlorination - chlorine

STONEY POINT WATER TREATMENT PLANT

EXECUTIVE SUMMARY
DRINKING WATER SURVEILLANCE PROGRAM, 1986

The Stoney Point Water Treatment Plant was sampled 10 times in 1986; results are given for raw and treated samples.

The parameters analyzed fall into several categories: physical parameters and general chemistry, bacterial parameters, metals, and organic substances including volatile and chloroaromatic substances and pesticides.

The discussion of results focuses on health-related parameters found in treated water:

(a) **Organic Substances**

Analysis was carried out for approximately 110 organic compounds. The only volatile compounds found, trihalomethanes (THMs) were always present in treated waters; the highest level recorded for total THMs was 75 ug/L.

None of the pesticides analyzed for was found.

No chlorophenolic compounds were analyzed for.

Three chloroaromatic compounds were found in treated water. Hexachloroethane was found once at 12 ng/L as was 1,2,3,5-tetrachlorobenzene at 31 ng/L, while 2,3,6-trichlorotoluene was found twice at 50 ng/L and 26 ng/L.

(b) **Other Parameters**

The aesthetic ODWO* for organic nitrogen was exceeded in three treated water samples. Of the other physical, general chemistry and microbiological parameters and metals analyzed, for which there are health-related ODWO, none exceeded the objectives, in treated water.

The results of these analyses are consistent with those obtained in other areas of the Great Lakes.

The treated water from the supply did not exceed any known health-related guidelines for organic substances applicable to drinking water.

---

* The Ontario Drinking Water Objectives, revised 1983.

STONEY POINT WATER TREATMENT PLANT

SUMMARY TABLE OF RESULTS
DRINKING WATER SURVEILLANCE PROGRAM, 1986

The Stoney Point Water Treatment Plant was sampled 10 times in 1986.

PARAMETER CATEGORY	TYPE OF SAMPLE RAW	TREATED*
1. GENERAL CHEMISTRY - includes anions such as sulphate, field analyses such as chlorine residual and physical parameters such as colour.		
Total number of parameters in category: 21		
- Total number of analyses completed	180	180
- Total number of positive results	178	133
- **Number of times guidelines exceeded**	**N/A**	**3**
Guidelines exceeded - aesthetic ODWO** for organic nitrogen (3)		
2. METALS - includes metals such as copper and lead.		
Total number of parameters in category: 24		
- Total number of analyses completed	191	210
- Total number of positive results	95	96
- **Number of times guidelines exceeded**	**N/A**	**0**
3. BACTERIOLOGY - includes bacteria such as coliforms.		
Total number of parameters in category: 5		
- Total number of analyses completed	34	39
- Total number of positive results	25	4
- **Number of times guidelines exceeded**	**N/A**	**0**
4. VOLATILES - includes compounds such as benzene and toluene; also included in this category are trihalomethanes (5 parameters), acknowledged to be produced during water treatment.		
Total number of parameters in category: 29		
- Total number of analyses completed	277	249
- Total number of positive results	0	36
- **Number of times guidelines exceeded**	**N/A**	**0**
5. PESTICIDES -		
Total number of parameters possible in category: 65		
- Total number of analyses completed	246	222
- Total number of positive results	0	0
- **Number of times guidelines exceeded**	**N/A**	**0**
6. CHLOROAROMATICS AND CHLOROPHENOLS - includes a range of chlorinated organic compounds.		
Total number of parameters possible in category: 19		
- Total number of analyses completed	130	114
- Total number of positive results	0	4
- **Number of times guidelines exceeded**	**N/A**	**0**

* Total number of analyses completed will not always equal the number of parameters analyzed for multiplied by number of times the supply was sampled, because of accidents during shipping or analyses or analytical difficulties.

** Ontario Drinking Water Objective.

DRINKING WATER SURVEILLANCE PROGRAM

The Drinking Water Surveillance Program (DWSP) for Ontario is a computerized drinking water information system. The objectives of this program are to provide:

- immediate, reliable, current information on drinking water quality,
- a flagging mechanism for 'Objective' exceedence,
- a definition of contaminant levels and trends,
- a comprehensive background for remedial action,
- a framework for assessment of new contaminants,
- an indication of treatment efficiency of plant processes.

Program

The DWSP began in April 1986 and is designed to eventually include all municipal water supplies in Ontario. Water supply locations have been prioritized for surveillance, based primarily on such criteria as population density, probability of contamination and geographical location.

Once the data base becomes established, an assessment of monitoring requirements for the future will be made; monitoring will be continued at the initial locations at an appropriate level and further locations will be phased on to the program as resources permit. It is

estimated that after 4 years of operation, the program will be monitoring 90 locations.

A major goal of the program is to collect valid water quality data, in context with plant operation characteristics in the plant at the time of sampling.

Assessments are carried out at all locations prior to sampling in order to acquire full plant process and distribution system details, and to designate (and retrofit if necessary) all sampling systems and locations.

Samples are taken of the raw (ambient water quality) and treated water at the treatment plants, and also in the distribution systems. In order to determine possible effects of distribution on water quality, both standing and flowing water in old and new sections of the distribution system are sampled. Sampling is carried out by Ministry of the Environment (MOE) Regional staff and/or Municipal personnel who have been trained in the applicable procedures. Comprehensive sampling kits and documented sampling procedures are made available to samplers. This ensures that samples are taken and shipped according to standard protocols and that field testing will supply reliable data. All analyses are carried out using approved documented procedures.

Data Reporting Mechanism

Final analytical results are usually received by the DWSP reporting system within 6 weeks of the time of sampling. At this time, printouts of the completed analyses are sent to the MOE District Officer and the appropriate MOE regional office, and are also retained by the DWSP co-ordinator. The DWSP is able to monitor analysis results and assess trends. Should the level of

a contaminant exceed a health-related Ontario Drinking Water Objective, action is required as outlined in the publication, Ontario Drinking Water Objectives.* The DWSP issues an "Action Alert" which notifies appropriate MOE and health authorities, and supplies a history of the occurrence of the contaminant in the water supply system concerned.

Parameters Analyzed

About one hundred and forty (140) different parameters are routinely measured on DWSP covering microbiological, organic and inorganic substances of concern, as well as process parameters.

Parameters included in the program are based on the following criteria:

- probability that the substance has the potential to cause problems (health-related or aesthetic);
- probability of occurrence in ambient water;
- availability of routine analytical and sampling methods for monitoring and control purposes;
- feasibility of control.

The range of parameters includes those having Ontario Drinking Water Objectives (ODWO), World Health Organization Drinking Water Guideline values, or other

---

* Ontario Drinking Water Objectives, revised 1983, published by the Ontario Ministry of the Environment.

jurisdiction's drinking water objectives (e.g. State of California) as well as compounds of concern to other agencies such as the International Joint Commission, and U.S. Environmental Protection Agency.

The parameters monitored routinely during 1986 are shown in Table 1; this table also includes available guidelines which are appropriate for drinking water, and the analytical detection limit (the lowest concentration that can be detected by laboratory analysis) for each parameter.

Analyses for additional pesticides may be included on certain sampling dates; such additional pesticides are selected from the list shown in Table 1A. These analyses may be done on a seasonal basis, in response to an identified concern or because of a potential for occurrence in certain locations. Seasonal analyses for specified additional pesticides are normally carried out at times corresponding to maximal agricultural use or run-off periods, i.e. in spring and fall seasons.

Drinking Water Guidelines

The Ministry of the Environment published a revised edition of "Ontario Drinking Water Objectives" in 1983.

The primary purpose of drinking water objectives is the protection of the health of the public consuming the water. Aesthetic considerations may also provide a basis for drinking water objectives, since the water should be pleasant to drink. The control of such aspects of water quality as hardness, corrosiveness, etc. is also important. The limits set are considered to outline the minimum requirements necessary to fulfill the above objectives, and may be either health-related or related to aesthetic and other considerations.

Because this survey covered such a large number of parameters, many of them did not have an ODWO. In order to be able to compare data results to health guidelines, it was necessary to refer to objectives and guidelines developed by other jurisdictions.

The footnotes to Table 1 indicate the sources and derivation of the various guidelines.

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED

PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit	PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit
CHEMISTRY:			Barium	1 mg/L	0.001 mg/L
Conductivity	-	0.01 UMHO/CM	Boron	5 mg/L	0.02 mg/L
			Beryllium	-	0.001 mg/L
Hardness	-	0.5 mg/L	Cyanide	0.2 mg/L	0.001 mg/L
Calcium	-	0.1 mg/L	Cadmium	0.005 mg/L	0.0003 mg/L
Magnesium	-	0.05 mg/L	Cobalt	-	0.001 mg/L
Sodium	-	0.1 mg/L	Chromium	0.05 mg/L	0.001 mg/L
Alkalinity		0.2 mg/L	Copper	1 mg/L	0.001 mg/L
pH	-	-	Mercury	1 µg/L	0.01 µg/L
Fluoride	2.4 mg/L	0.01 mg/L	Molybdenum	-	0.001 mg/L
Chloride	250 mg/L	0.2 mg/L	Nickel	-	0.002 mg/L
Residue total (solids)	-	1 mg/L	Lead	0.05 mg/L	0.003 mg/L
Turbidity	1 FTU	.01 FTU	Selenium	0.01 mg/L	0.001 mg/L
Phosphorus	-	0.002 mg/L	Strontium	-	0.001 mg/L
Phosphates	-	0.0005 mg/L	Vanadium	-	0.001 mg/L
Nitrogen Total Kjeldahl	0.15 mg/L*	0.1 mg/L	Zinc	5 mg/L	0.001 mg/L
Ammonium Total	-	0.05 mg/L			
Colour	5 TCU	0.5 TCU	BACTERIOLOGY (RAW ONLY):		
Nitrates Total	10 mg/L as N	.05 mg/L	Total Coliform MF	-	0
			Total Coliform MF BKGD	-	0
Nitrite	1 mg/L as N	0.0005 mg/L	Fecal Coliform	-	0
			Standard Plate Count MF	-	0
METALS:			(TREATED ONLY):		
Uranium	0.02 mg/L(t)	0.002 mg/L‡	Present/Absent (P/A) Test	Absent	Absent
Iron	0.3 mg/L	0.002 mg/L	Total Coliform MF BKGD	-	0
Manganese	0.05 mg/L	0.001 mg/L	Fecal Coliform	0	0
Aluminum	-	0.003 mg/L	Standard Plate Count MF	<500 orgs/mL	0
Arsenic	0.05 mg/L	0.001 mg/L			

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED (cont'd)

PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit	PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit
VOLATILES:			CHLOROAROMATICS:		
1,1-Dichloroethylene	0.3 µg/L(h)	1.0 µg/l	Hexachloroethane	19000 ng/L(e)	1 ng/L
Dichloromethane	40 µg/L(c)	5 µg/L	1,3,5-Trichlorobenzene	10000 ng/L(y)	5 ng/L
TRS-1,2-Dichloroethylene	-	1 µg/L	1,2,4-Trichlorobenzene	15000 ng/L(y)	5 ng/L
1,1-Dichloroethane	-	1 µg/L	Hexachlorobutadiene	4500 ng/L(e)	1 ng/L
Chloroform	350 µg/L++	1 µg/L	1,2,3-Trichlorobenzene	10000 ng/L(y)	5 ng/L
1,1,1-Trichloroethane	1000 µg/L(c)	1 µg/L	2,4,5-Trichlorotoluene	-	5 ng/L
1,2-Dichloroethane	10 µg/L(h)	1 µg/L	2,3,6-Trichlorotoluene	-	5 ng/L
Carbon Tetrachloride	3 µg/L(h)	1 µg/L	1,2,3,5-Tetrachloro-benzene	-	1 ng/L
Benzene	10 µg/L(h)	1 µg/L	1,2,4,5-Tetrachloro-benzene	38000 ng/L(e)	1 ng/L
1,2-Dichloropropane	-	1 µg/L	2,6,A-Trichlorotoluene	-	5 ng/L
Trichloroethylene	30 µg/L(h)	1 µg/L	1,2,3,4-Tetrachloro-benzene	-	1 ng/L
Dichlorobromomethane	350 µg/L++	1 µg/L	Pentachlorobenzene	74000 ng/L(e)	1 ng/L
Toluene	100 µg/L(c)	1 µg/L	Total PCB's	3000 ng/L(t)	20 ng/L
1,1,2-Trichloroethane	6 µg/L(e)	1 µg/L			
Chlorodibromomethane	350 µg/L++	1 µg/L			
Tetrachloroethylene	10 µg/L(h)	1 µg/L			
Chlorobenzene	100-300 ng/L(h)*	1 ng/L			
Trifluorochlorotoluene	-	1 µg/L	PESTICIDES:		
Ethylbenzene	1400 µg/L(e)	1 µg/L	Hexachlorobenzene	10 ng/L(h)	1 ng/L
Ethylene Dibromide	0.02 µg/L(x)	1 µg/L	Heptachlor	3000 ng/L+++	1 ng/L
P-Xylene	620 µg/L(c)	1 µg/L	Aldrin	700 ng/L**	1 ng/L
M-Xylene	620 µg/L(c)	1 µg/L	PP-DDE	d	1 ng/L
O-Xylene	620 µg/L(c)	1 µg/L	Mirex	-	5 ng/L
Total Trihalomethanes	350 µg/L++	3 µg/L	Alpha BHC	700 ng/L(c)	1 ng/L
Bromoform	350 µg/L++	1 µg/L	Beta BHC	300 ng/L(c)	1 ng/L
1,1,2,2-Tetrachloroethane	1.7 µg/L(e)	1 µg/L	Gamma BHC (Lindane)	4000 ng/L	1 ng/L
1,4-Dichlorobenzene	400 µg/L(e)	1 µg/L	Alpha Chlordane	7000 ng/L***	2 ng/L
1,3-Dichlorobenzene	400 µg/L(e)	1 µg/L	Gamma Chlordane	7000 ng/L***	2 ng/L
1,2-Dichlorobenzene	400 µg/L(e)	1 µg/L	Oxychlordane	-	2 ng/L

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED (cont'd)

PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit	PARAMETER CATEGORY	Objective Guideline (1)	Detection Limit
Pesticides (cont'd)					
OP-DDT	30000 ng/L(d)	5 ng/L			
PP-DDD	d	5 ng/L			
PP-DDT	d	5 ng/L			
Methoxychlor	100000 ng/L	5 ng/L			
Heptachlor Epoxide	3000 ng/L+++	1 ng/L			
Endosulfan 1	74000 ng/L(ea)	2 ng/L			
Dieldrin	700 ng/L**	2 ng/L			
Endrin	200 ng/L	4 ng/L			
Endosulfan 2	74000 ng/L(ea)	4 ng/L			
Endosulfan Sulphate	-	4 ng/L			
Octachlorostyrene	-	1 ng/L			
Toxaphene	5000 ng/L	PA(xx)			

Footnotes:

(l) = Ontario Drinking Water Objectives (ODWO) for drinking water, unless noted.

(t) = ODWO Interim maximum acceptable concentration (IMAC) for drinking water.

(c) = California State Department of Health Action Level for drinking water.

(d) = ODWO for DDT (contains other isomers such as OPDDT and PPDDT).

(e) = US EPA ambient guideline; guideline levels when it is assumed that untreated water and fish and shellfish are consumed from the same body of water.

(ea) = United States Environmental Protection Agency (US EPA) ambient level for endosulfan (contains other isomers).

(h) = World Health Organization (WHO) guideline for drinking water.

(h)* = World Health Organization (WHO) Odour Threshold for drinking water.

(x) = State of Florida, maximum contaminant level for drinking water.

(xx) = the presence of toxaphene is detected in scan used; positive samples would be quantified by special additional analysis.

(y) = New York State (Taste and Odour) proposed drinking water guideline.

++ = total Trihalomethanes.

+++ = combined total; Heptachlor and Heptachlor Epoxide.

* = total Kjeldahl Nitrogen minus Ammonia Nitrogen.

** = total of Aldrin and Dieldrin.

*** = Chlordane is a mixture of alpha and gamma isomers.

‡ = Analysis changed to mass spectrometry method in mid-1986, detection limit 0.0001 mg/L.

TABLE 1A: DRINKING WATER SURVEILLANCE PROGRAM SPECIAL PESTICIDES

Dicamba
2,4-D
2,4-DB
2,4-DP
2,4,5-T
Silvex (2,4,5-TP)
Picloram
2,4,6-Trichlorophenol
2,4,5-Trichlorophenol
2,3,4-Trichlorophenol
2,3,5,6-Tetrachlorophenol
2,3,4,5-Tetrachlorophenol
Pentachlorophenol
Diazinon
Dichlorvos
Dursban
Ethion
Guthion
Malathion
Mevinphos
Methyl Parathion
Methyl Trithion
Parathion
Phorate (Thimet)
Reldan
Ronnel
Carbofuran
Propoxur
IPC
Aminocarb
CIPC
Eptam
Benomyl
Bux
Diallate
Sevin
Sutan
Propazine
Atrazine
Simazine
Sencor (metribuzin)
Bladex (Cyanazine)
Prometone
Ametryne
Prometryne
Atratone
Alachlor
Metolachlor

RESULTS AND DISCUSSION

The parameters analyzed fall into several categories: physical parameters and general chemistry (chemistry), bacterial parameters, metals, and organic substances including volatile and chloroaromatic substances and pesticides. Many of the substances analyzed for are naturally-occurring or treatment by-products.

The results of analysis of raw and treated water samples are shown in Tables 2 and 3. Table 2 shows the categories of parameters analyzed, as well as the total number of analyses which were completed in each category for both raw and treated water samples and the total number of positive results which were obtained. Table 3 lists the sampling dates and the numerical values for each parameter for which analysis produced a positive (quantifiable) result.

The Stoney Point Water Treatment Plant was sampled 10 times in 1986.

(a) Non Organic Substances

There are 311 positive results of 360 reported analyses for physical parameters, such as pH and temperature and general chemistry tests. The results of these tests are used as an indication of the analytical validity and integrity of the samples, the general characteristics of the water, and as a guide to making an assessment of the treatment process; they may also indicate whether any changes occur during the time elapsing between sampling and actual analysis. Organic nitrogen exceeded the aesthetic ODWO in three treated water samples; levels of organic nitrogen above the limit can result in taste and odour problems.

Positive results were obtained for 29 analyses for bacterial parameters out of a total number reported of 73. These bacterial tests include those for species of paramount importance from a public health point of view, and those which assess the general bacteriological quality and characteristics of the water; by this means, a measure is obtained of the overall efficiency of water treatment processes. Two of the positive results obtained for treated water samples were for standard plate count (a measure of the total number of bacteria in a water sample) with the highest count being 3 organisms per mL; the ODWO recommend that treated water not exceed 500 organisms per mL for standard plate count.

Analyses of 401 tests for metals in the water samples were reported; of these 191 were positive results. Metals can occur naturally and most are generally regarded as being ubiquitous. However, some may be present in water as a result of industrial or other discharges. A small number of metals have public health significance.

Of those parameters discussed above for which there are ODWO, none exceeded the Objectives except for organic nitrogen. Nor did the levels exceed any guidelines for drinking water set by other jurisdictions, such as the U.S. Environmental Protection Agency (US EPA), the World Health Organization (WHO) and Health & Welfare, Canada (H&W, Canada). Furthermore, the results of these analyses are consistent with those obtained in other areas of the Great Lakes.

(b) Organic Substances

Of a total of 526 analyses for volatile organic compounds, only 36 were positive; these were from treated water samples and were all due to the presence of trihalomethanes.

Trihalomethanes (THMs) are acknowledged to be produced during the water treatment process and will almost always only occur in treated waters. Trihalomethanes are comprised mainly of chloroform, chlorodibromomethane and dichlorobromomethane with bromoform occurring occasionally. Results are reported for the individual compounds as well as for their sum, which is expressed as total trihalomethanes (total THM). The ODWO for total THM is 350 ug/L; this level was not exceeded in any of the water samples included in this report, the highest level recorded being 75 ug/L on March 18, 1986.

Four hundred and twenty eight (428) tests were carried out for twenty three different pesticides; none was found above trace levels. Nine special pesticides were analyzed for in both raw and treated water on two occasions (May 13, 1986 and December 15, 1986); this analysis is carried out only once or twice a year at each supply, on a seasonal basis, to correspond to the use and/or loss of such pesticides on agricultural land. The nine analyzed for were propazine, atrazine, simazine, Sencor, Bladex, prometone, ametryne, prometryne and atratone. Alachlor and metolachlor were two additional pesticides analyzed for on December 15, 1986. No special pesticides were found in raw or treated water samples. No analysis for chlorophenolic compounds was carried out.

Only three other organic compounds were found at quantifiable levels in treated water at this supply; these were all chloroaromatics, thus providing the 4 positive results out of a total of 244 analyses in this category. Hexachloroethane was found at 12 ng/L; while no ODWO exists for this compound, the US EPA has recommended an ambient water quality criteria (assuming both fish and untreated water are consumed from the same body of water over a lifetime) of 19000 ng/L.

1,2,3,5-tetrachlorobenzene was detected at 31 ng/L on June 18, 1986. There is no ODWO for this compound, nor is there any specific ambient water quality criteria. However, the 1,2,4,5-tetrachlorobenzene isomer, which is chemicaly similar, is considered to be the most toxic of the tetrachlorobenzene isomers. Thus, the 38000 ng/L US EPA ambient water quality criteria for 1,2,4,5-tetrachlorobenzene, can be applied to the 1,2,3,5-tetrachlorobenzene isomer with an extra margin of safety.

The chemical 2,3,6-trichlorotoluene was detected at 50 ng/L and 26 ng/L. It has been found in treated water at other supplies, as have other trichlorotoluene isomers (Drinking Water Survey, St. Clair-Detroit River Area*). There is no drinking water guideline for this substance.

Review of these results, along with information from other DWSP sites*, would indicate that certain chlorinated compounds, such as hexachloroethane,

---

* Drinking Water Survey, St. Clair-Detroit River Area. Update August 1986. Ontario Ministry of the Environment.

and trichlorotoluenes appear more frequently in the treated water than in the raw water. The Ministry of the Environment (MOE) made a submission to the liaison group of the Canadian Council of Resource and Environment Ministries and the Federal/ Provincial Advisory Committee on Environmental and Occupational Health (ACEOH) to consider setting drinking water guidelines for these compounds. The information will be forwarded to the ACEOH sub-committee on drinking water guidelines; MOE provides a representative for this sub-committee.

CONCLUSIONS

The data reveal that for metals, inorganic ions, and bacterial parameters, raw water values are frequently in the detectable range; levels of metals and inorganics are also found in treated water. The levels of metals, inorganic compounds, and bacteria are consistent with those found in other water supplies in the province.

For the organic compounds, most are below detection levels, even though the most sophisticated equipment available was employed in the chemical analysis.

ODWO have not been established for some of the compounds analysed; for these few compounds, use was made of appropriate guidelines set by other agencies, such as the World Health Organization, the US Environmental Protection Agency, Health and Welfare Canada or other agencies. None of these guidelines was exceeded.

The report identifies some compounds detected for which drinking water guidelines are not yet available. These compounds have been submitted for consideration for setting drinking water guidelines to the appropriate expert groups by the Ministry of the Environment.

The treated water at the supply did not exceed any known health-related guidelines for organic substances applicable to drinking water.

TABLE 2

STONEY POINT WATER TREATMENT PLANT

	PARAMETER GROUP	TYPE OF SAMPLE RAW	TREATED
1.	GENERAL CHEMISTRY		
	- Total samples	180	180
	- Total positives	178	133
2.	METALS		
	- Total samples	191	210
	- Total positives	95	96
3.	BACTERIOLOGY		
	- Total samples	34	39
	- Total positives	25	4
4.	VOLATILES		
	- Total samples	277	249
	- Total positives	0	36
5.	PESTICIDES		
	- Total samples	226	202
	- Total positives	0	0
6.	CHLOROAROMATICS		
	- Total samples	130	114
	- Total positives	0	4
7.	CHLOROPHENOLS		
	- Total samples	Not analyzed	
	- Total positives		
8.	SPECIAL PESTICIDES		
	- Total samples	20	20
	- Total positives	0	0

Table 3

STONEY POINT WATER TREATMENT PLANT OWSP RESULTS

02/11/87

PARAMETERS	UNITS		SAMPLE DATE											
			86/01/06	86/01/15	86/01/29	86/02/26	86/03/18	86/04/07	86/04/21	86/05/13	86/06/18	86/12/15		
ALKALINITY	MG/L-CAC	R	114.80	115.40	98.000	198.80	181.30	98.700	99.40	115.50	92.200	103.10		
		T	95.400	58.800	84.000	174.40	162.10	79.200	68.200	72.600	71.000	78.100		
ALUMINUM	MG/L-AL	R	.061	.150	.240	.200	.330	.380	.590	.330		.880		
		T	.180	.065	.086	.170	.220	.047	.034	.320	.051	.069		
BARIUM	MG/L-BA	R	.013	.015	.014	.025	.023	.014	.018	.019		.019		
		T	.016	.015	.012	.020	.018	.013	.014	.015	.017	.014		
BORON	MG/L-BO	R	.040	.060		.060				.040		.030		
		T	.040	.050	.030	.040	.040			.030	.020	.020		
CALCIUM	MG/L-CA	R	42.000	43.500	35.800	81.000	75.000	35.300	34.400	40.000	31.600	37.700		
		T	42.400	43.800	35.500	80.000	76.000	38.700	34.100	33.900	31.700	37.000		
CHLORIDE	MG/L-CL	R	13.600	14.000	13.200	39.600	49.800	12.400	11.600	14.550	9.500	12.500		
		T	16.200	15.000	14.400	42.200	52.500	14.450	12.300	13.500	11.000	15.000		
COLOUR	HZU	R	15.500	14.000	15.500	20.500	14.500	13.000	6.500	5.000	7.500	11.000		
		T				4.000	5.000							
CONDUCTIVITY	UMHO/CM	R	322.00	324.00	293.00	606.00	588.00	277.00	265.00	315.00	249.00	288.00		
		T	329.00	346.00	300.00	600.00	598.00	309.00	272.00	280.00	259.00	301.00		
COBALT	MG/L-CO	R					.001							
		T												
CHROMIUM	MG/L-CR	R	.002	.002	.002	.003	.003	.002		.001		.001		
		T	.002	.002	.002	.003	.003	.002						
COPPER	MG/L-CU	R	006	.007	.009	.011	.025	.015	.015	.014		.002		
		T	.009	.004	.004	.007	.008	.006	.001	.004	.003	.002		

Table 3 (cont'd)

STONEY POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

PARAMETERS	UNITS		SAMPLE DATE											
			86/01/06	86/01/15	86/01/29	86/02/26	86/03/18	86/04/07	86/04/21	86/05/13	86/06/18	86/12/15		
FECAL COLIFORM MEMBRANE FILTRATION	CT/100ML	R										14.000 A3C		
		T												
IRON	MG/L-FE	R	.006	.130	.210	.160	.280	.350	.630	.320		.830		
		T	.180		.014	.013	.017	.004		.039	.003	.010		
FLUORIDE	MG/L-F	R	.130	.120	.100	.170	.180	.110	.100	.130	.120	.120		
		T	.110		.060	.140	.150	.060	.040	.150	.060	.060		
FIELD COMBINED CHLORINE RESIDUAL	MG/L-CL	R												
		T	1.400		.100		.200	1.200	1.430	.300	.200	1.620		
FIELD FREE CHLORINE RESIDUAL	MG/L-CL	R												
		T	1.500	1.000	.800		.700	1.500	1.100	1.200	.800	1.500		
FIELD TOTAL CHLORINE RESIDUAL	MG/L-CL	R												
		T	1.900		.900	1.000	.900	2.300	1.500	1.500	1.000	1.720		
FIELD PH		R	7.400	7.800	7.800	7.800	7.800	7.800	7.800	7.800	7.600	7.600		
		T	7.200	7.300	7.400	7.300	7.200	7.400	7.400	7.400	7.300	7.600		
FIELD TEMPERATURE	DEG.C	R	3.000	4.000	2.000	3.500	3.000	8.500	9.000	15.000	19.000	2.000		
		T	3.500	5.000	5.000	4.000	5.000	10.000	8.200	15.100	19.000	2.000		
FIELD TURBIDITY	FTU	R	3.000	3.000	5.000					10.600	20.000	30.000		
		T	1.000	.100	.200				.300	.260	.150	.350		
HARDNESS	MG/L-CAC	R	148.00	151.00	126.00	270.00	247.40	122.50	120.00	139.50	111.50	131.50		
		T	148.00	152.00	126.00	265.00	250.70	133.00	119.00	118.50	111.50	128.00		
STANDARD PLATE COUNT MEMBRANE FILT.	CT/ML	R	143.00					370.00						
		T						3.000	1.000					
MERCURY	UG/L-HG	R	.050	.010		.010						.030		
		T	.050	.050	.050	.010	.030	.060				.040		

Table 3 (cont'd)

STONEY POINT WATER TREATMENT PLANT DWSP RESULTS 02/11/87

PARAMETERS	UNITS		SAMPLE DATE 86/01/06	86/01/15	86/01/29	86/02/26	86/03/18	86/04/07	86/04/21	86/05/13	86/06/18	86/12/15		
MAGNESIUM	MG/L-MG	R	10.300	10.300	9.000	16.450	14.600	8.300	8.350	9.550	7.900	9.100		
		T	10.250	10.350	9.150	15.800	14.800	8.850	8.250	8.250	7.800	8.750		
MANGANESE	MG/L-MN	R	.002	.004	.005	.008	.013	.008	.014	.010		.011		
		T	.005	.003	.002	.003	.003	.002	.001	.001		.001		
MOLYBDENUM	MG/L-MB	R				.001								
		T				.001								
SODIUM	MG/L-NA	R	7.500	7.000	7.500	21.300	25.500	6.600	7.200	9.000	6.000	7.200		
		T	7.500	7.500	7.500	21.300	25.500	6.900	6.700	7.200	6.000	7.000		
NICKEL	MG/L-NI	R	.001	.001	.001	.002	.003	.001	.002					
		T	.002	.001	.001	.002	.002	.001						
AMMONIUM TOTAL	MG/L-N	R	.018		.016	.082	.096	.012	.024	.020	.024	.024		
		T	.008	.008	.008		.008		.008	.020	.020			
NITRITE	MG/L-N	R	.008	.011	.012	.063	.060	.023	.013	.045	.010	.017		
		T			.004			.005		.003				
TOTAL NITRATES	MG/L-N	R	1.410	1.540	1.100	4.390	4.310	1.190	.705	1.100	.655	1.120		
		T	1.370	1.550	1.100	4.350	4.410	1.400	.575	.610	.575	1.100		
NITROGEN TOTAL KJELDAHL	MG/L-N	R	.290	.270	.270	.600	.670	.370	.500	.330	.260			
		T	.160	.070	.150	.390	.390	.130		.090	.070			
PH		R	8.080	8.090	8.160	7.690	8.050	8.260	8.200	8.280	8.270	8.330		
		T	7.220	6.580	7.600	7.350	7.770	7.370	7.620	7.380	7.660	8.020		
PHOSPHORUS FIL REACT	MG/L-P	R	.007	.005	.005	.040	.042	.015	.008	.006	.011	.006		
		T			.003									

Table 3 (cont'd)

STONEY POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

PARAMETERS	UNITS		SAMPLE DATE 86/01/06	86/01/15	86/01/29	86/02/26	86/03/18	86/04/07	86/04/21	86/05/13	86/06/18	86/12/15		
PHOSPHORUS TOTAL	MG/L-P	R	.017	.023	.018	.058	.083	.051	.110	.030	.036	.045		
		T		.007			.013							
TOTAL SOLIDS	MG/L	R	209.00 CRO	211.00 CRO	190.00 CRO	402.00	385.00	183.00	264.00	205.00 CRO	182.00	194.00		
		T	214.00 CRO	225.00 CRO	195.00 CRO	403.00	389.00	201.00 CRO	177.00 CRO	182.00 CRO	168.00 CRO	179.00		
STRONTIUM	MG/L-SR	R	.130	.140	.120	.320	.300	.120	.120	.150		.130		
		T	.140	.130	.120	.310	.290	.130	.100	.120	.120	.130		
TOTAL COLIFORM MEMBRANE FILTRATION	CT/100ML	R	4.000 A3C	4.000 A3C	106.00 A3C	500.00	142.00 A3C	20.000 A3C	15.000 A3C	1.000	6.000 A3C	142.00 A3C		
		T												
TOTAL COLIFORM BACKGROUND MF	CT/100ML	R	510.00	560.00	2900.0	1500.0	1000.0	1120.0	3000.0	280.00	5000.0	6000.0		
		T	1.000									1.000		
TURBIDITY	FTU	R	6.200	5.500	6.400	4.700	11.400	16.100	64.000	12.600	19.800	26.000		
		T										.300		
URANIUM	UG/L-U	R										.620		
		T												
VANADIUM	MG/L-V	R				.003	.001		.001	.001		.002		
		T				.003								
CHLOROFORM	UG/L	R												
		T		14.000	39.000	49.000	54.000	24.000	12.000	48.000	38.000	24.000		
DICHLOROBROMOMETHANE	UG/L	R												
		T		7.000	17.000	16.000	15.000	10.000	7.000	18.000	16.000	12.000		
CHLORODIBROMOMETHANE	UG/L	R												
		T		12.000	13.000	8.000	6.000	6.000	7.000	5.000	7.000	3.000		
1235 TETRACHLOROBENZENE	NG/L	R												
		T									31.000			

Table 3 (cont'd)

STONEY POINT WATER TREATMENT PLANT OWSP RESULTS

02/17/8

PARAMETERS	UNITS		SAMPLE DATE 86/01/06	86/01/15	86/01/29	86/02/26	86/03/18	86/04/07	86/04/21	86/05/13	86/06/18	86/12/15		
HEXACHLOROETHANE	NG/L	R												
		T								12.000				
236 TRICHLOROTOLUENE	NG/L	R												
		T			50.000						26.000			
TOTAL TRIHALOMETHANES	UG/L	R												
		T		33.000	69.000	73.000	75.000	40.000	26.000	71.000	61.000	39.000		
ZINC	MG/L-ZN	R	.004	.006	.008	.008	.009	.006	.009	.006		.005		
		T	.005	.010	.005	.005	.005	.007	.005	.031	.005	.004		